

Certificate



Cyber Security

www.tuv.com
ID 0600000000

No.: 968/CSP 1037.00/25

Product tested	PLCnext Control	Certificate holder	Phoenix Contact GmbH & Co. KG Flachsmarktstr. 8 32825 Blomberg Germany
Type designation	AXC F 1152, AXC F 2152, AXC F 3152, AXC F XT SPLC 1000, RFC 4072S, NFC 482S, BPC 9102S		
Codes and standards	IEC 62443-4-1:2018 (Edition 1.0)	IEC 62443-4-2:2019 (Edition 1.0)	
Intended application	The PLCnext Control complies with the requirements according to IEC 62443-4-1 and Security Level Capability 2 (SL-C 2) according to IEC 62443-4-2.		
Specific requirements	The PLCnext Control is only valid in the dedicated security context as documented in the user manuals. The instructions of the associated user manuals released by manufacturer must be considered. The current versions of the product are specified in the currently valid Revision List. The Revision List is released by the manufacturer in cooperation with the certification body.		

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/CSP 1037.00/25 dated 2025-07-04.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2025-07-04

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. (FH) Sergei Biberdorf

www.fs-products.com
www.tuv.com



TÜVRheinland®
Precisely Right.